

**INSTALLED BACKFLOW DEVICES
MUST BE AT LEAST 12 INCHES FROM
ANY WALL AND MUST BE BETWEEN 30
- 53 INCHES FROM THE FLOOR.**