

Guidelines For Smoke and Carbon Monoxide Alarm Requirements

Massachusetts – Residential Dwelling Units

Year Built or Substantially Modified	↓ Before 1975 ↓	↓ 1975 - 8/27/97 ↓	↓ 8/27/97 – 2008 ↓	↓ 9/1/08 – 2/11 ↓	↓ 2/11 – Present ↓
--------------------------------------	-----------------	--------------------	--------------------	-------------------	--------------------

All Smoke Alarms Shall Be Ceiling Mounted

Smoke Alarm Power Supply:	Battery or Hardwired	Hardwired, interconnected	Hardwired, interconnected w/battery backup	Hardwired, interconnected w/battery backup	Hardwired, interconnected w/battery backup
---------------------------	----------------------	---------------------------	--	--	--

Type of Smoke Alarm Technology: (Photoelectric or Ionization)

On the same level, If a required detector is located More Than 20 ft. from a kitchen or full bathroom doorway it shall be: →	** Photoelectric with a sealed 10 year non rechargeable, non-replaceable battery.	Photoelectric OR Ionization	Photoelectric OR Ionization	Photoelectric OR <u>Dual Detector</u> *	Photoelectric Only
On the same level, If a required detector is located Within 20 ft. of kitchen or full bathroom doorway it shall be: →	** Working smoke alarms installed prior to 12/1/16 (that met requirements) can continue to be used until they are 10 years old	Photoelectric OR Ionization	Photoelectric Only	Photoelectric Only	Photoelectric Only

Smoke Alarm Placement

On every habitable level & including the basement level on the CEILING ; at the base of each stairway leading to an occupied floor above. →	Smoke	Smoke	Smoke	Smoke	Smoke
On CEILING outside each Sleeping Area (in hallway)	Smoke	Smoke	Smoke	Smoke	Smoke
Inside every Bedroom →	Not Required	Not Required	Smoke	Smoke	Smoke
Finished Attic (Habitable) →	Smoke	Smoke	Smoke	Smoke	Smoke
Garage (Attached) →	Not Required	Not Required	Not Required	Heat Detector	Heat Detector

Carbon Monoxide (CO) Alarm Power Supply & Placement

Battery or Plug-In w/battery backup: →	Allowed	Allowed	Allowed	Not Allowed	Not Allowed
Hardwired, interconnected w/battery backup:	Allowed	Allowed	Allowed	Required	Required

Alarm Placement: A CO alarm shall be located on each habitable level, including finished portions of basements and attics. A CO alarm shall be placed in the hallway OUTSIDE each separate sleeping area (where bedrooms are located), no farther than 10 ft. from ANY bedroom door.

▶▶▶▶ EFFECTIVE 1/1/2015 SMOKE ALARMS OLDER THAN 10 YEARS MUST BE REPLACED WITH NEW ALARMS. ◀◀◀◀

* **Dual Technology Smoke Alarms** consists of one SMOKE alarm with both photoelectric and ionization technology & must have Hush Feature.

● **One Smoke Alarm** is needed for each 1,200 square feet of area, per floor. CO Alarms only have a 5, 7 or 10 year life span.

● **Combination Smoke & Carbon Monoxide Alarms** MUST have a Tone and Voice Feature. If battery powered, must have a 10 year sealed non rechargeable, non-replaceable battery.

Revised 4/12/2016

This document is a guideline. Please call your Fire Prevention Office if you still have questions.